



Office of University Building Official

4400 University Drive, MS 1E4; Fairfax, VA 22030

Telephone: (703) 993-6070

Electrical Inspection Guide

Temporary Service

- Fairfax & Mason Square (Arlington) Campuses: Consult the Dominion Energy Blue Book requirements: [Blue Book \(azureedge.net\)](http://azureedge.net)
- Sci-Tech (Manassas) Campus: Consult the NOVEC website at: [Installation of Electric Service - Commercial \(novec.com\)](http://novec.com)
- Services installed pursuant to NEC Article 230.
- Overcurrent protection for feeders and branch circuits pursuant to NEC Article 240.
- GFCI receptacles for personnel pursuant to NEC Article 590.

Under slab/Underground

- Cable and conduit burial depths pursuant to NEC Table 300.5.
- Grounding electrode(s) connections and bonding pursuant to NEC Article 250.

Rough-In

- Electrical panels require inspection with covers off prior to being energized.
- Electrical components including conduit paths, supports, wiring, electrical boxes, etc.
- Technology, telecom, and other low voltage wiring including conduit paths, supports, wiring, telecom/data boxes.
- Fire stopping of penetrations through rated assemblies.

Above Ceiling

- Electrical components located above hard (drywall/plaster) and/or suspended ceilings including conduit paths, supports, wiring, electrical boxes, etc.
- Technology, telecom, and other low voltage wiring including conduit paths, supports, wiring, telecom/data boxes.
- Fire stopping of penetrations through rated assemblies.

Final

- Lighting controls, GFCI receptacles, panel directories, and equipment labeling.
- All covers installed and labeled to include new or revised arc flash labels as required.
- Dedicated equipment and panelboard space and working clearances.
- Fire stopping of penetrations through rated assemblies.
- Removal of all temporary power and lighting installations.