



Office of University Building Official

4400 University Drive, MS 1E4; Fairfax, VA 22030

Telephone: (703) 993-6070

Means of Egress Inspection Guide

- Completion of all exit components
- Accessible egress and door operator hardware
- Exit signage
- Means of egress emergency lighting systems
- Completion of exterior exit discharge areas
- Special locking devices/systems
- Posting of occupant loads per requirements of USBC
- Approved exit access for all areas which may involve the placement of furniture, shelving, tables, seating etc. (by owner's items)
- Area of refuge
- Panic hardware or fire exit hardware
- No obstructions greater than allowed by the Code shall be in the egress path.